

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 190

Dated: 01-03-2024

It is certified that an inspection team headed by ...Sbri Manoj Kumar Paikva

(Name of Officers with designation) from ...P.H.E. Sub. Div. Kurud PHED

inspected the ...K.C.P.S. Kurud.....

(Name & Address of the school) on 01/03/2024..(date of inspection) and on the basis of

Water Test Report (Attached) bearing no..... dated...01/03/2024

of P.H.E. Sub. Div. Lab. Kurud..... (PHED Lab) certified that


the K.C.P.S. Kurud.....( Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till ...28/02/2025

Signature with Seal:   
Name: Shri P. S. Gajendra  
Designation: Sr. De. O.  
Name & Address of the Office / Department : .....

To Principle  
K.C.P.S. Kurud  
(Name & Address of the Institution)


Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies


**BLOCK WATER TESTING LABORATORY**  
**PUBLIC HEALTH ENGINEERING DEPARTMENT**  
**SUB DIVISION - KURUD (C.G.)**  
**REPORT ON WATER SAMPLE ANALYSIS**

BLOCK- Kurud  
 SAMPLING DONE BY- K.C.P.S. Teacher  
 DATE OF SAMPLE RECEIVED BY LAB 01.03.2024  
 DATE OF TESTING 01.03.2024

कैलीशम चंडाकर पब्लिक स्कूल कुरुद

S.N.	water Quality parameter	unit of measurement	BIS permissible limit	BIS Desirable limit	Test result				
					I	II	III	IV	V
					K.C.P.S. S. Kurud				
1	2	3	4	5	6	7	8	9	10
1	Alkalinity	mg/l	600	200	260				
2	Calcium (as ca)	mg/l	200	75	76				
3	Chloride	mg/l	1000	250	70				
4	Coliform	MPN/100ml	0	0	Nil				
5	Fluride	mg/l	1.5	1.0	0.78				
6	Total Hardness	mg/l	600	200	250				
7	Iron	mg/l	1.0	0.3	0.017				
8	Magnesium (as mg)	mg/l	100	30	14.58				
9	Nitrate	mg/l	45	45	0				
10	PH	mg/l	8.5	6.5	7.1				
11	Residual Chlorine	mg/l	1	0.2	0				
12	Sulphates	mg/l	400	200	Nil				
13	TDS	mg/l	2000	500	310.8				
14	Turbidity	mg/l	5.0	1.0	0.18				
15	Conductivity	mg/l	2000	500	638.9				
Remark									

  
 Assistant  
 Chemist  
 Block Water Testing Lab  
 PHED Kurud (C.G.)

  
 Assistant Engineer  
 PHE sub Division  
 Kurud (C.G.)